

Choose certainty Add value.

Dalian SANYO Compressor Co., Ltd. No.8 Songlan St. 116600 Eco. & Tech. Deve. Zone, Dalian

PEOPLE'S REPUBLIC OF CHINA

## Motor - compressor

Project number

Technical certifier

Fax extension

Page

R.I4000904901

Mr.Zhao Yong

+86 10 65906186-301 yong.zhao@tuv-sud.cn +86 10 65906182

22 April 2009

1

## Certificate issue letter

Dear Mr. Guo Jian,

We are pleased to attach your certificate No.: B 09 04 40189 023, which entitle you to label your certified product(s) with the respective certification mark. Let us give you some additional information which we consider to be important for you.

- The product has to be accompanied by a user manual and safety label/warning mark in the language of the country where it is supposed to be sold.
- . To ensure that the validity of the certificate is not put at risk please inform us about any change in your production or of the product itself.
- . The certification will allow you to sell your products easier and with less risk.
- . The annual license fee will be 19 units for maintaining these advantages.
- · Factory inspection should be performed periodically according to certification requirements for maintaining the products' conformity in production and your advantages.

Further information for the use of our mark is contained in our testing and certification regulations. We look forward to our co-operation and will assist you at any time.

Yours sincerely,

Zhao Yong

Technical certifier/ TÜV SÜD Product service, CRT3

Bank of China Beijing Landmark Tower Sub-Branch Account No:803715059908092001 (USD) 803715059908092001 (RMB) SWIFT Code: BKCHCNBJ110

Telephone: +86 10 6590 6186 Telefax: +86 10 6590 6182

www.tuv-sud.cn

TÜV®

TÜV SÜD China, Beijing Branch Unit 918, Landmark Tower 2 8 North Dong sanhuan Road Beijing 100 004 P.R. China





## CERTIFICATE

No. B 09 04 40189 023

Holder of Certificate: Dalian SANYO Compressor

Co., Ltd.

No.8 Songlan St.

116600 Eco.& Tech. Deve.Zone, Dalian PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: Compressors

Motor - compressor

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. The certification mark must not be altered in any way. See also notes overleaf.

Test report no.:

BJ4000904901

Date, 2009-04-21

Page 1 of 2







## CERTIFICATE No. B 09 04 40189 023

C-SB263H8A, C-SB303H8A Model(s):

> C-SB353H8A, C-SB373H8A C-SB373H8F, C-SB453H8A C-SB373H8D, C-SBN263H8A C-SBN303H8A, C-SBN353H8A C-SBN373H8A, C-SBN373H8B C-SBN453H8A, C-SBS120H38L

Parameters:

Rated voltage:

3~, 380-415VAC/3~, 440VAC 50/60Hz

Rated frequency: Degree of protection:

IP00

Refrigerant:

R22 (C-SB263H8A, C-SB303H8A C-SB353H8A, C-SB373H8A C-SB373H8F, C-SB453H8A

C-SB373H8D)

R407C (C-SBN263H8A, C-SBN303H8A

C-SBN353H8A, C-SBN373H8A C-SBN373H8B, C-SBN453H8A

C-SBS120H38L)

Construction:

Built-in

Tested according to:

EN 60335-1/A13:2008 EN 60335-2-34/A1:2005

EN 62233:2008

Production Facility(ies):

40189

Page 2 of 2