

Plant Safety Limited
Parklands
Wilmslow Road
Didsbury
Manchester M20 2RE



Plant Safety

EC Type Examination Certificate

Certificate No. 18730/B/1

PSL Contract No. 18730

Manufacturer: Henry Technologies Ltd	
Address: Mossland Rd Hillington Industrial Estate Glasgow	
Responsible Person: Engineering Manager	Date of Submission: 23/1/02
Year of Manufacture: 2002	Design Code: AD Merkblatt

Description of Pressure Equipment:

Model/type: S-5414 Helical Separator
Drawing Nos: A3973 Rev F
PWHT: None
Serial numbers of inspected items: 68446 - 68455

Technical Documentation

Selection of Materials:	PMA's
Joining Procedures	Approved by Plant Safety Ltd
NDE Personnel	Approved by British
Application of harmonized standards	None
Calculation review:	Satisfactory

REFERENCE ONLY
NOT TO BE USED FOR
MANUFACTURE

Conclusions of examination


The pressure equipment specified above has been examined and found to comply with the applicable essential safety requirements specified in the Pressure Equipment Regulations 1999, (EC Pressure Equipment Directive 97/23/EC).

Special Conditions

This EC type approval Certificate is valid for a period of 10 years from the date of issue.

Any alterations, even of a minor nature, planned to be made to this approved Type, must be advised to Plant Safety Limited

Signed: _____



Date: April 30th 2002

Notified Body Reference No. 0041



EC type-examination Certificate

EC type-examination requested by:

Manufacturer: Henry Technologies
Address: Mossland Road
Hillington Industrial Estate
Glasgow G52 4XZ
Scotland

Responsible Person: Stuart Morrison

Date of submission: 15 May 2001

Description of Pressure Equipment:

Type: Safety Relief Valve

Group 1 valves (0.25" orifice size):-

Model no 526E-CE - Drg no 526E-CE Rev A
Model no 5230A-CE - Drg no 5230A-CE Rev A
Model no 5231A-CE - Drg no 5231-A-CE Rev A
Model no 5231B-CE - Drg no 5231-B-CE Rev A

Conclusions of examination

The technical documentation and pressure equipment specified above has been examined and found to comply with the essential requirements specified in the EC Pressure Equipment Directive 97/23/EC.


Special Conditions

This EC type approval Certificate is valid for a period of 10 years from the date of issue and may be renewed.

Certificate No. 18730/B/2

PSL Contract No. 18730

Signed:



Date: 30 May 2002

Any alterations, even of a minor nature, planned to be made to this approved equipment, must be advised to Plant Safety Limited

Notified Body Reference No. 0041